# Non Domestic Gas Safety Record

Cert. No. 195

**Clima Heating Services Ltd**

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure No detailed internal inspection of flues (integrity, construction and lining) has been carried out.

## Company / Installer

| | |
|---|---|
| Engineer | [redacted] |
| Company | Clima Heating Services Ltd |
| Address | 14 |
| | Flockton Crescent |
| | Sheffield |
| | South Yorkshire |
| Post Code | S13 9QR |
| Tel No. | [redacted] |
| Gas Safe Reg | [redacted] |
| ID Card No. | [redacted] |

## Job Address

| | |
|---|---|
| Name | UoS Accommodation Village |
| Address | Yarncliffe AB |
| | Endcliffe Village |
| | Sheffield |
| | South Yorkshire |
| Post Code | S10 3EA |
| Tel. No | |

## Customer / LandLord

| | |
|---|---|
| Name | [redacted] |
| Company | Engie |
| Address | 14 |
| | Endcliffe Avenue |
| | Sheffield |
| | South Yorkshire |
| Post Code | S10 3EA |
| Tel. No | 01142 224948 |

## Appliance Details / Inspection Details

| | Location | Appliance Type | Make | Model | Flue Type | Landlord's Appliance | Appliance Inspected | Operating Pressure (mbar) | Heat Input (kW/h) | High Combustion Reading | | | Low Combustion Reading | | | Safety device(s) correct operation | Ventilation Provision satisfactory | Visual condition of flue and termination satisfactory | Flue Performance test | Appliance Serviced | Appliance safe to use |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | Ratio | CO ppm | CO2 % | Ratio | CO ppm | CO2 % | | | | | | |
| 1 | Plant Room | Water Heater | Andrews | CWH 60/200 (Burner 1) | FF | Yes | Yes | 18.5 | 29.9 | 0.0005 | 47 | 8.8 | 0.0000 | 7 | 8.3 | Yes | Yes | Yes | Pass | Yes | Yes |
| 2 | Plant Room | Water Heater | Andrews | CWH 60/200 (Burner 2) | FF | Yes | Yes | 18.5 | 29.9 | 0.0005 | 51 | 8.8 | 0.0000 | 4 | 8.3 | Yes | Yes | Yes | Pass | Yes | Yes |
| 3 | Plant Room | Water Heater | Andrews | CWH 60/200 (Burner 3) | FF | Yes | Yes | 18.5 | 31.2 | 0.0005 | 52 | 8.8 | 0.0000 | 6 | 8.3 | Yes | Yes | Yes | Pass | Yes | Yes |
| 4 | Plant Room | Water Heater | Andrews | CWH 60/200 (Burner 4) | FF | Yes | Yes | 18.5 | 31.2 | 0.0005 | 57 | 8.8 | 0.0000 | 5 | 8.3 | Yes | Yes | Yes | Pass | Yes | Yes |
| 5 | Plant Room | BOILER | Viessmann | Vitodens 300 WB3A - 66kW | FF | Yes | Yes | 17.5 | 65.6 | 0.0001 | 13 | 9.0 | 0.0000 | 8 | 8.8 | Yes | Yes | Yes | Pass | Yes | Yes |
| 6 | Plant Room | BOILER | Viessmann | Vitodens 300 WB3A - 66kW | FF | Yes | Yes | 17.0 | 64.8 | 0.0002 | 12 | 9.0 | 0.0000 | 2 | 9.2 | Yes | Yes | Yes | Pass | Yes | Yes |

## Defects / Identified

| | | Labels and Warning Notice Issued |
|---|---|---|
| 1 | | No |
| 2 | | No |
| 3 | | No |
| 4 | | No |
| 5 | | No |
| 6 | | No |

Emergency Control Accessible Yes

Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

**NEXT INSPECTION DUE ON OR BEFORE** 14-Sep-2022

## Comments

## Signatures

Issued by: Signed [redacted]

Print Name [redacted]

Received by: Signed

Print Name [redacted]

Date 14-Sep-2021